


STANDARD NOTES:

1. REFER TO SECTION 02530 FOR ADDITIONAL REQUIREMENTS ASSOCIATED WITH THE CONSTRUCTION OF MANHOLE INVERTS.
2. ABOVE DIMENSIONS FOR STANDARD 48" DIAMETER MANHOLES AND GRAVITY SEWER CONSTRUCTION.
3. MAXIMUM CHANGE IN DIRECTION FOR FLOW STREAM SHALL BE 90 DEGREES.

<p>Water Pollution Control Authority Town of Canton</p>  <p>4 Market Street P.O. Box 168 Collinsville, Connecticut 06022</p>	<p>SEWER CONSTRUCTION DETAIL</p> <p>GUIDELINES FOR CONSTRUCTION OF STANDARD MANHOLE INVERTS</p> <p style="text-align: right;">NO SCALE</p>		
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">LATEST REVISION: 2/07</td> <td style="width: 50%;">NO. 005</td> </tr> </table>	LATEST REVISION: 2/07	NO. 005
LATEST REVISION: 2/07	NO. 005		