


**STANDARD NOTES:**

1. UNLESS OTHERWISE DIRECTED BY THE WPCA OR ITS TECHNICAL CONSULTANT, MINIMUM PITCH FOR 6" SERVICE LATERALS SHALL BE 1/4" PER FOOT.
2. PROPOSED LOCATIONS OF SERVICE LATERALS TO BE COORDINATED IN THE FIELD WITH THE WPCA OR ITS TECHNICAL CONSULTANT.
3. IF ROCK IS PRESENT, IT SHOULD BE EXCAVATED AT LEAST 10- FEET BEYOND THE END OF THE STUB WITHIN THE RIGHT OF WAY OR SEWER EASEMENT.
4. REFER TO SECTION 02515 FOR ADDITIONAL REQUIREMENTS ASSOCIATED WITH GRAVITY SEWER SERVICES.
5. FOR NEW SEWER SERVICE CONNECTIONS TO EXISTING GRAVITY SEWER MAINLINE PIPES, THE WPCA OR ITS TECHNICAL CONSULTANT SHALL SPECIFY THE METHOD OF CONNECTION.
6. CURB STOPS SHALL BE IN THE CLOSED POSITION DURING THE TIME OF CONSTRUCTION.
7. PIPE SIZE FOR LOW PRESSURE LATERALS SHALL BE NO LESS THAN 1-1/2".
8. IF DIRECTED BY THE WPCA OR ITS TECHNICAL CONSULTANT, MARKER POST CAN BE LEFT 6" ABOVE FINISHED GRADE.

 <p><b>Water Pollution Control Authority</b> <b>Town of Canton</b></p> <p>4 Market Street P.O. Box 168 Collinsville, Connecticut 06022</p>	<b>SEWER CONSTRUCTION DETAIL</b>	
	<b>LOW PRESSURE SEWER SERVICE CONNECTION TO GRAVITY SEWER SERVICE LATERAL</b>	
	LATEST REVISION: 2/07	NO. 011