


STANDARD NOTES:

1. PROPOSED LOCATIONS OF SERVICE LATERALS TO BE COORDINATED IN THE FIELD WITH THE WPCA OR ITS TECHNICAL CONSULTANT.
2. IF ROCK IS PRESENT, IT SHALL BE EXCAVATED AT LEAST 10- FEET BEYOND THE END OF THE STUB WITHIN THE RIGHT OF WAY OR SEWER EASEMENT.
3. REFER TO SECTION 02515 FOR ADDITIONAL REQUIREMENTS ASSOCIATED WITH LOW PRESSURE SEWER SERVICE LATERALS.
4. IF DIRECTED BY THE WPCA OR ITS TECHNICAL CONSULTANT, MARKER POST CAN BE LEFT 6" ABOVE FINISHED GRADE.



Water Pollution Control Authority
Town of Canton

4 Market Street
P.O. Box 168
Collinsville, Connecticut 06022

SEWER CONSTRUCTION DETAIL

LOW PRESSURE SANITARY
SEWER SERVICE LATERAL

NO SCALE

LATEST REVISION: 2/07

NO. 020