


**STANDARD NOTES:**

1. SEWAGE COMBINATION VALVE TO BE SUPPORTED INDEPENDENTLY FROM THE PIPE. USE 3/4" MIN STAINLESS STEEL THREADED RODS.
2. PROVIDE 5'-0" QUICK CONNECT HOSE ASSEMBLY AT EACH SEWAGE COMBINATION VALVE FOR BACK WASHING.
3. SIZE OF INTERNAL DUCTILE IRON PIPING TO MATCH DIAMETER OF FORCE MAIN PIPE SIZE.
4. REFER TO SECTION 02530 FOR ADDITIONAL REQUIREMENTS ASSOCIATED WITH LOW PRESSURE SEWER PRECAST STRUCTURES.

 <p>Water Pollution Control Authority Town of Canton</p> <p>4 Market Street P.O. Box 168 Collinsville, Connecticut 06022</p>	SEWER CONSTRUCTION DETAIL	
	FORCE MAIN IN-LINE AIR RELEASE, FLUSHING & CLEANOUT STRUCTURE	
	LATEST REVISION: 2/07	NO. 029